mod paperwork

UST Inspecti	ion Checklist 1075# 14000 17707	
PART I. OWNER/OPER	ATOR INFORMATION	
1. Facility Name: <u>Jonia Max Prison</u>	6. Date of Visit 905077. Marketer: Non-Marketer:	
2. Owner:	8. Site Arrival/Departure (Time):	
3. Operator:	9. Facility Address: 1576 Bluewater Hwy	
5. Contact Person: Doogh Thalin	Ionia, MI 48846	
6. UST Site Phone #: 6/6 - 527 - 633/x 260	10: Team Members:	
PART II. UST SITE INFORMATION		
1. Tank #: 1 2 3	4 5 6 7	
2. Tank Type: See		
3. Piping Type: Steel		
4. Size of Tank: <u>6K</u> <u>6K</u> <u>3K</u>		
5. Tank Contents: (no desel desel		
6. Install Date: <u>1986</u> <u>1986</u> <u>1984</u>		
7. TTT Date:		
8. LTT Date:		
9: LD (Tank): Vapor Monitoring	· · · · · · · · · · · · · · · · · · ·	
10: LD (Pipe): Vapor Monitorina - Suc	HON	
11. Closure Date:		
PermTempPermTempPermTemp	Perm Temp Perm Temp Perm Temp	
12. Spill: Yes No Yes No Yes No	Yes No Yes No Yes No	
13. Overfill: Yes No Yes No Yes No Type: Foot	Yes No Yes No Yes No Yes No	
	Yes No Yes No Yes No Yes No	
Date: 5-2-200/		
	Yes No Yes No Yes No Yes No	
Date: 5-2-2007		
Type: CP test- All passed		
16. CP Monitoring: [For all cathodic protection systems (Galvanic Anodes and Imp 6 Mo./3 Yrs: Yes No Yes No Yes No		
Note: Monitoring conducted within six month of installation and three years after Six Months: Yes No Yes No Yes No	r initial monitoring. [280.31(b)(1)]	
Note: Monitoring conducted within six month of any repairs to UST system. [28]	0.33(e)] Yes No Yes No Yes No Yes No	
Note: Records on file of last two monitoring results. [280.31(d)(2)]	10 10 10 10 10	
17. CP Monitoring: [For Impressed Current Systems Only] 60 Day Insp.: Yes No Yes No Yes No	Ver No Ver No Ver No Ver No	
Note: System is inspected ever 60 days, involvers reading and recording systems	voltage and amperage. [280.31(c)]	
Records: Yes No Yes No Yes No Note: Records on file of last three voltage and amperage readings. [280.33(d)(1)]	Yes No Yes No Yes No	

UST Inspection Checklist		
PART III. RECOMMENDATION(S) & NARRATIVE COMMENTS		
No further action is recommend/necessary: Yes No Notes:	5. Notice of Violation (NOV): Yes No Date:	
Notes:	[If Yes, A Full Narrative Report is required along with this checklist] 6. Field Citation (FC): Yes No Date:	
Notes:	Notes: [If Yes, A Full Narrative Report is required along with this checklist]	
3. Follow-up inspection recommended: Yes No	7. Administrative Order (AO): Yes No Date:	
Notes: State reason(s) why.]	Notes: [If Yes, A Full Narrative Report is required along with this checklist]	
4. Information Request Letter (IRL): Yes No Date:	8. Refer to State: Yes No Date:	
Notes: [If Yes, A Full Narrative Report is required along with this checklist]	Notes: [If Yes, A Full Narrative Report <u>may</u> be required along with this checklist]	
9. Financial Responsibility (FR): Yes No Expiration Date: Self Insural		
10. Inspector's Remarks:		
- Vapor Monitorina being used for hD-tankst piping. Facility does have log book will all readings going back 5 years. - Bacharach is vapor monitoring davice. % ching checking to see when last calabraged.		
regarding Vapor monitoring placement of testing Stations & oteract compliance w/		
- lang Monitors one abstace & out of date DE G. well some Mose list of mobes who he fan furchase the		
Inspector Signature 3/25/09 Date		

Great Lakes Compliance Co. CorPreTek, Inc.

07 MM 7: 16

P.O. Box 429, Carson City, MI 48811 Tel: (989) 584-6505 Fax: (989) 584-6405

June 3, 2007

Mr. Chuck Haskins Ionia Maximum Security Prison 1576 W. Bluewater Hwy. Ionia, MI 48846

Reference:

Cathodic Protection Survey Ionia Maximum Security Prison

1576 W. Bluewater Hwy.

Ionia, Michigan

Gentlemen,

On May 2, 2007, CorPreTek conducted a cathodic protection survey of the above referenced facility. The purpose of this follow-up survey was to assess the effectiveness of the recently installed cathodic protection system.

According to the information provided to us, the structures intended for cathodic protection consist of (2) 6,000 gallon and (1) 3,000 gallon STIP3 underground storage tanks, with their respective metallic product piping.

Based on the field data attached, all of the tanks and product piping are cathodically protected in accordance with one of the criteria established by NACE International. Specifically, a negative (cathodic) voltage of at least 850 mV with the current applied has been achieved at each test location. We recommend all cathodic protection systems be tested on an annual basis.

We appreciate the opportunity to have provided our services to you for this project. Should you have any questions regarding any of the enclosed information, please do not hesitate to call us.

Sincerely,

CorPreTek, Inc.

Larry Brandon President

Cathodic Protection Specialist #5001

Compliance

Solutions

and

Corrosion

Prevention

IONIA MAXIMUM SECURITY PRISON 1576 W. BLUEWATER HWY. IONIA, MICHIGAN **CATHODIC PROTECTION SURVEY**

FIELD DATA

Surveyed by: CorPreTek (DO)

Survey date: May 2, 2007

Comments: 1. Structure-to-electrolyte potential data recorded in volts versus a

portable Cu/CuSO4 reference electrode.

2. ON = energized reading.

Location	ON
6,000 Gallon Gasoline Tank Endpoint Center Endpoint	-1.32 -1.26 -1.20
6,000 Gallon Diesel Tank Endpoint Center Endpoint	-1.21 -1.27 -1.32
3,000 Gallon Diesel Tank Endpoint Center Endpoint	-1.02 -0.99 -1.03
Gasoline Piping Diesel Piping Backup Generator Piping	-1.22 -1.22 -0.90



STATE OF MICHIGAN

DEPARTMENT OF ENVIRONMENTAL QUALITY WASTE AND HAZARDOUS MATERIALS DIVISION

FACILITY INSPECTION REPORT

Owner Name & Address:

MDOC - Ionia Maximum Prison Attn Doug Thelen 1576 W Bluewater Hwy Ionia, MI 48846 Location of Tanks:

MDOC - Ionia Maximum Prison 1576 W Bluewater Hwy Ionia, MI 48846-8594 County - Ionia Facility ID - 00033665

ATTENTION: MDOC - Ionia Maximum Prison

A Records Investigation was conducted on December 3, 2009, for the above-referenced facility for compliance with Part 211, Underground Storage Tank Regulations, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451); the Michigan Underground Storage Tank Rules (MUSTR), 1999 AACS R 29.2101 et seq.; and the applicable sections of the rules for the Storage and Handling of Flammable and Combustible Liquids, 2003 AACS R 29.5101 et seq. The inspection showed that there was no action taken by the inspector.

Two regulated underground tanks were removed from the ground on this date. No later than January 3, 2010, an amended registration form is required to Lansing, showing that the tanks have been removed. No later than January 18, 2010, the site assessment report along with the site assessment results are required to Lansing, unless a confirmed release has been reported.

The inspection and violations (if any) were discussed with Leak Petroleum at the time of the inspection.

If you have additional questions concerning this matter, please contact me.

Chad Sietsema

Hazardous Materials Storage Inspector

Sie Beno-

Grand Rapids District Office

350 Ottawa Avenue., NW - Unit 10

Grand Rapids, MI 49503-2341

Phone: (616) 356-0219

Fax: (616) 356-0202

Email: sietsemac@michigan.gov

12-7-0

Date



